





SECTION Y-Y



SECTION X-X




DETAIL A
SCALE 1 : 2




DETAIL B
SCALE 1 : 2

CONNECTOR ASSEMBLY




Recommended Steps for Installation:

1. Drill 10 mm hole for frame cable grommet.
2. De-bur hole using hand held file.
3. Utilize silicone Dow 795 or similar adhesive to secure grommet in hole.
4. Feed frame cable through the grommated hole with the connection point remaining in the glazing pocket. (SSG applications may require a cutout slot allowing the connection of the pigtail and frame cable to sit flush and not disrupt the smooth finish of the SSG).
5. If factory glazed, pigtail and frame cable are to be assembled inside the glazing pocket during the factory assembly of IGU and frame cable to be protected during transport and installation at site. Protect pigtail and frame cable at all times.
6. Glazier must label frame cable to match corresponding IGU per wiring daigram. If not enough room inside glazing pocket, bring the pigtail to frame cable connection out to a suitable location.
7. While installing glass, connect the pigtail to the frame cable and create a service loop in the glazing pocket.
8. Finish glazing ensuring none of the wires are pinched or damaged.
9. Cable bundled at the mullion exit to be protected.
10. Use the provided Field Wiring Tester after each frame cable is routed through the frame.
11. This drawing shows frame cable routing options, but other options may work as well or better. Service loop, protecting, testing, and labelling the frame cable is required.




SECTION Z-Z
SCALE 4 : 1



SageGlass		SAGE Electrochromics Inc.	
ALL DIMENSIONS ARE IN "inches"		DRAWING SHEET	A1
DRAWN BY	TSS	REVISION	APPROVED BY DATE
CHECKED BY			
DESCRIPTION :			
YCW 750 XT			
SCALE: 1:5	DATE: 10-10-2022	SHEET NO	1 OF 7

ASSEMBLED FRAME



- ① -VERTICAL
- ② -HEAD
- ③ -HORIZONTAL
- ④ -SILL
- ⑤ -LEFT JAMB
- ⑥ -RIGHT JAMB
- ⑦ -SAGEGLASS

THIS DRAWING IS THE PROPERTY AND COPYRIGHT OF SAGE ELECTROCHROMICS INC. ANY REPRODUCTION, REPRODUCTION OR USE WITHOUT WRITTEN CONSENT IS PROHIBITED. DO NOT SCALE THE DRAWING.	 SAGE Electrochromics Inc.		DRAWING SHEET		A1			
	ALL DIMENSIONS ARE IN "inches"				REVISION		APPROVED BY DATE	
	DRAWN BY	TSS		REVISION		APPROVED BY DATE		
	CHECKED BY			REVISION		APPROVED BY DATE		
DESCRIPTION :						SHEET NO		2 OF 7
YCW 750 XT						SCALE: 1:5		DATE : 10-10-2022

CONNECTOR ASSEMBLY - VERTICAL MULLION



FRAME CABLE EXITING THE GLAZING POCKET OF THE MULLION

CONNECTOR ASSEMBLY INSIDE GLAZING POCKET OF VERTICAL




9
PIGTAIL LABEL

REFERENCE TAG

SERVICE LOOP

8



DETAIL C
SCALE 1 : 1

- ⑧ -CONNECTOR ASSEMBLY
- ⑨ -GROMMET

SAGE Electrochromics Inc.

ALL DIMENSIONS ARE IN "inches"

DESCRIPTION :
YCW 750 XT

SCALE: 1:10 DATE : 10-10-2022


DRAWN BY	TSS	REVISION	APPROVED BY DATE
CHECKED BY			

DRAWING SHEET A1

SHEET NO 3 OF 7


THIS DRAWING IS THE PROPERTY AND COPYRIGHT OF SAGE ELECTROCHROMICS INC. REPRODUCTION OR USE WITHOUT WRITTEN CONSENT IS PROHIBITED. DO NOT SCALE THE DRAWING.

CONNECTOR ASSEMBLY - HORIZONTAL MULLION



		SAGE Electrochromics Inc.	
<small>ALL DIMENSIONS ARE IN "inches"</small>		DRAWING SHEET	A1
DRAWN BY	TSS	REVISION	APPROVED BY DATE
CHECKED BY			
DESCRIPTION : YCW 750 XT			
SCALE: 1:10	DATE: 10-10-2022	SHEET NO	4 OF 7

FRAME CABLE ROUTING




PROTECT FRAME CABLE FROM SHARP EDGE OF MULLION

FRAME CABLE MAY EXIT MULLION THROUGH BACK AND OR THROUGH TOP

9

FRAME CABLES EXITING MULLION



DETAIL F
SCALE 1 : 1

9 -GROMMETS

SageGlass **SAGE Electrochromics Inc.**

ALL DIMENSIONS ARE IN "inches"

DESCRIPTION :
YCW 750 XT

SCALE: 1:5 DATE : 10-10-2022

DRAWING SHEET	A1
DRAWN BY	TSS
CHECKED BY	
REVISION	APPROVED BY DATE



THIS DRAWING IS THE PROPERTY AND COPYRIGHT OF SAGE ELECTROCHROMICS INC. REPRODUCTION OR USE WITHOUT WRITTEN CONSENT IS PROHIBITED. DO NOT SCALE THE DRAWING.

FACTORY GLAZED FRAME AND REF TAGS

PROTECT FRAME CABLE FROM SHARP EDGE OF MULLION

FRAME CABLES COILED, SECURED AND PROTECTED BEFORE AND DURING TRANSPORTATION TO SITE

FRAME CABLE MAY EXIT MULLION THROUGH BACK AND OR THROUGH TOP



DETAIL G
SCALE 1 : 2

REFERENCE TAGS


FACTORY ASSEMBLED VIEW
BEFORE INSTALLATION

⑨ -GROMMETS


		SAGE Electrochromics Inc.	
<small>ALL DIMENSIONS ARE IN "inches"</small>		DRAWING SHEET	A1
DRAWN BY	TSS	REVISION	APPROVED BY DATE
CHECKED BY			
DESCRIPTION : YCW 750 XT			
SCALE: 1:8	DATE : 10-10-2022	SHEET NO	6 OF 7

THIS DRAWING IS THE PROPERTY AND COPYRIGHT OF SAGE ELECTROCHROMICS INC. REPRODUCTION OR USE WITHOUT PERMISSION IS PROHIBITED. DO NOT SCALE THE DRAWING.

TEST SET UP FOR 4C FRAME CABLE



TEST SET UP FOR 2C FRAME CABLE



CONNECTIONS:

TO FRAME CABLE:

1. Connect adapter cable with alligator clips to tester cable.
2. All alligator clips must be connected to a wire:
 - a. If 4-Conductor frame cable, connect each alligator clip to the corresponding frame cable wire.
 - b. If 2-Conductor frame cable, connect red and white alligator clips to red frame cable wire and black and green alligator clips to black frame cable wire.
3. Connect ground cable to earth ground. (mullion / framing system)

TO IGU PIGTAILS:

1. Connect tester cable to IGU pigtail. Ground cable is not used.

DIRECTIONS:

Turn on power. Wait at least 5 seconds until the result is displayed on the screen. Press TEST button to restart the test.

		SAGE Electrochromics Inc.	
ALL DIMENSIONS ARE IN "inches"		DRAWING SHEET	A1
DRAWN BY	TSS	REVISION	APPROVED BY DATE
CHECKED BY			
DESCRIPTION : YCW 750 XT			
SCALE: 1:1	DATE: 10-10-2022	SHEET NO	7 OF 7